# KARNATAKA ANTIBIOTICS AND PHARMACEUTICALS LIMITED

### **BULK DRUG - 7ACA Project**

Pre-Bid Queries Dt. 24.03.2023

Minimum fill pitch of 19mm is acceptable. Noise level of 65 db is acceptable. If CTI certification is not available the design shall be certified by IIT.	You have requested a CTI-certified cooling tower assembly in the tender.  CTI is offered certification to the entire range of cooling towers by random testing of a single tower in the series and does not allow any customization in the certified tower shall be certified by IIT.	(0)	Maya Cooling Towers	10
GST is applicable.	We request you to confirm any special concession avaialale to you for GST. GST applicable on cooling tower is 18%.			9
Un changed	We can not accept the given payment terms. Please approve 15% advance, 80 % against readiness of material at our factory, 5% against installation.			8
Yes, the delivery time line shall be 6-8 months from the date of issue of PO.	Time of completion shall be 6 month fromt the date of order.	,		7
Open space will be provided to the vendor	Necessary covered storage space near to cooling tower shall be provided by customer.	1		6
The civil work shall be in KAPL scope for providing the RCC basin with necessary accessories.	RCC basin with necessary accessories shall be in client scope			0.0
The bid submission to be addressed as per tender to Bangalore address.	We request you to confirm the bid submission address( i.e. at Banglore or Madhyapradesh)	ı.		4
Please refer clause No- 17.3 of the tender doucment.	We request you provide us your bank details for preparation of EMD.	•);		ω
Acceptable	PVC fill spacing shall be 19mm flute size in place of 25mm.	ı		2
Acceptable	Testing and Performance testing shall be done at site in presence of customer Necessary flow rate measuremen shall be done by customer. Inlet /outlet temp and wet bulb measurment shall be done by supplier to establish the capacity as per the performance chart. Testing by CTI certifed agency shall not be applicable.	uč	PAHARPUR COOLING TOWERS LIMITED	1
KAPL Clarifications	Queries Raised	Bid Document Ref. No.	Company Name	Sl. No.
KAPY BDP/C8/3253	NOTE: This Prebid Queries is part of the tender document and this supercedes the clauses of Tender	t of the tender document and this	NOTE: This Prebid Queries is par	
Tender Ref no:	er	Cooling Tower		
FIG. DIN GRETTES Dr. 74.03.7073				ľ

KARNATAKA ANTIBIOTICS AND PHARMACEUTICALS LIMITED  BULK DRUG - 7ACA Project  Pre-Bid Queries Di		
	Pre-Bid Queries Di	
I . La I		
	I . La I	

Only OEM shall participate in the tender,	Sir, we are not only the OEM for cooling towers but also have supplied various cooling tower components for most world-renowned OEMs. (B&W, Spig, Hamon, L&T, BHEL, HAC, GEA, ENEXIO, Holtech, and many more ) Note - we request you to please let us know your take on this to make the participation decision in this tender.	9.	14
Minimum fill pitch of 19mm is acceptable. Noise level of 65 db is acceptable. If CTI certification is not available the design shall be certified by IIT.	We would request you to please increase the participation by removing this restriction as you have already kept the Validation in your scope of work therefore we are bound to demonstrate the performance of the tower as per clauses 1.6.2 to 1.8, also third-party testing can be performed as per clause 1.8, we are certainly ready to offer the verification of design and tower performance validation by any of the reputable agency you recommend.		13
Minimum fill pitch of 19mm is acceptable. Noise level of 65 db is acceptable. If CTI certification is not available the design shall be certified by IIT.	Considering these points supplied tower of any of the parties will not comply with the CTL but they will take the advantage of their certified cooling tower range on paper.	1	12
Minimum fill pitch of 19mm is acceptable. Noise level of 65 db is acceptable. If CTI certification is not available the design shall be certified by IIT.	As per your specification, your wise consultant has targeted a few very important technical points. fills pitch of 25mm (which is very important for nonclogging of fills and delivering longer life), a Noise restriction of 65 dB (Which is required for comfortable surroundings), and a restriction for RPM(required to control fan sound by controlling fan tip speed). Preference to the Lowest kW of the fan.	ŗ	¥.
KAPL Clarifications	Queries Raised	Bid Document Ref. No.	Sl. No. Company Name
KAPL   BDP   CS   3953	supercedes the clauses of Tender	NOTE: This Prebid Queries is part of the tender document and this supercedes the clauses of T	NOTE: This Prebid Queries is par
Tender Ref no:	er	Cooling Tower	
Pre-Bid Queries Dt. 24.03.2023			

### KARNATAKA ANTIBIOTICS AND PHARMACEUTICALS LIMITED **BULK DRUG - 7ACA Project**

17	16	15	Sl. No.	2			and the second
		8	Company Name	NOTE: This Prebid Queries is par			
ı	417	Ľ	Bid Document Ref. No.	NOTE: This Prebid Queries is part of the tender document and this supercedes the clauses of T	Cooling Tower		BUI
Material Hub and Material Fastener are contradictory, under fan fastener is used only in the hub which is mentioned as "Heavily galvanized M S or Al. Alloy Hubs with SS hardware" whereas again Material Fastener is mentioned as "Epoxy Coated MSHDGI" this should be also be SS/SS304/SS316.	At some point, the only option for Framework structure and support structure was given as GI/ MS HDG, but as per the latest development in the field, all such thing is also possible in "Pultruded FRP"(this offered robust performance and long lift) therefore I request you to please allow this option also.	Kindly check on the following typo error - Under "Annexure I Technical Datasheet - COOLING TOWER for Process" on line 16 "per cell heat rejection capacity" is mentioned as 1000, this need to be corrected. under the same cell in "Annexure I Technical Datasheet-COOLING TOWER for Process chiller," no data is present, which also needs your attention.	Queries Raised	s supercedes the clauses of Tender	er		BULK DRUG - 7ACA Project
All hardwares shall be of SS-304	Please quote as per tender. The vendor may quote their design also as an alternative with proper justification.	The observation is noted and it should be read as "500" instead of "1000".  The observation is noted in "Annexure I Technical Datasheet-COOLING TOWER for Process Cooling Tower" need to be calculated as per capacity and number of cells. (The revised technical data sheet is attached)	KAPL Clarifications	KAPL (BDP / CB ) 8263	Tender Ref no:	Pre-Bid Queries Dt. 24.03.2023	



# KARNATAKA ANTIBIOTICS AND PHARMACEUTICALS LIMITED

**BULK DRUG - 7ACA Project** 

Pre-Bid Queries Dt. 24.03.2023

NOTE: This Prebid Queries is part of the tender document and this supercedes the clauses of Tender **Cooling Tower** Tender Ref no:

Queries Raised

MAPL (BDP 3953

**KAPL Clarifications** 

\*\*\* Please add signatories

Sl. No.

Company Name

Bid Document Ref. No.

List of Vendor present for Pre-Bid Queries

PAHARPUR COOLING TOWERS LIMITED Maya Cooling Towers Blue Star Bhavin Shah Amit Chourasia Thara Nair

Yeshwanth Rao

(E - Mircobiology)

Goutam SVS (AM - QA)

Jagadish Chaparashekar (DGM – Mnance)

(AGM - Bulk Drug Project)

Somnath Datta

(SM - Purchase) Kanak Banot

(DGM-FD)

KAPL -Consultant K P Rajan

(GM-Technical Bulk Project)

(GM - Bulk Project) Sharesh Kumar

> (AGM - Finance) **B** Ramesh

(xours)

DGM - ABM & Supriya Kulka

KAPL - Consultant