



		<div>KARNATAKA ANTIBIOTICS AND PHARMACEUTICALS LIMITED Bengaluru-58</div> <div>BULK DRUG - 7ACA Project</div>		<div></div> <div>KARNATAKA ANTIBIOTICS &amp; PHARMACEUTICALS LIMITED</div>	<div>PRE BID QUERIES FOR ELECTRICAL HT WORK TENDER Dt.: 13<sup>TH</sup> OCTOBER-2023</div> <div>Tender Ref no : KAP/LBDP/CG/1482</div>	<div></div> <div>DOSHI CONSULTANTS PVT. LTD.</div>
NOTE: This Prebid Queries is part of the tender document and this supercedes the clauses of Tender						
A. TECHNICAL POINTS		PARTICULARS	SUPPLIER REMARKS	KAP/LDCPL COMMENTS/JUSTIFICATION		
Sl. No.	NAME OF THE COMPANY/VENDOR					
1	M/s Konsteelc Engineers Ltd	As per the qualification criteria "Vendor must have experience of 11KV or 33 KV Capacitor bank supply and installation, within the last 3 years"	We have experience in supply and installation of 6.6KV/AR capacitor banks. Please refer enclosed work order reference for IOCL Mannad.	No deviation		
2	M/s Konsteelc Engineers Ltd	"Similar works means supplying, erection, supervision, testing and commissioning of 33 KV 4 pole structure 33/11 KV HT work as specified in point 1 of reputed organization"	We have experience in supply, installation, erection, testing and commissioning of 33KV 2 pole structure. Please refer enclosed work order reference for IOCL Guntkal	No deviation		
3		<b>As per Qualification Criteria:</b> The bidder should possess valid A class electrical contractor license issued from the any state government for electrical installation related work	<b>As per Qualification Criteria:</b> The bidder should possess valid A class electrical contractor license issued from the any state government for electrical installation related work. Kindly clarify which clause shall prevail. On Award of the work, we shall obtain the Electrical Contractor's License for carrying out the work in Madhya Pradesh.	<b>As per local norms bidder should have "A" class license from MP PWD and should have register with MPPKWVCL.</b>		
4	M/s SRR Projects Pvt Ltd	<b>As per ITB:</b> Should have Valid Electrical Contractor's License for carrying out the work in Madhya Pradesh on the date of submission of technical bid of the Tender. Please clarify the Civil works scope for the Transformers and HT Switch Board		Please refer Section VII of scope of work clause 2, all civil work are exclude from scope of work		
5		We Request you to specify transformers Losses and levels & Type (i.e. Code)		a)The losses for 8 MVA 33/11 KVA transformer shall be 5.5 KW + 40 KW, b) The losses for 2500 KVA 33/415 V transformer shall be at 50% - 6.372 KW and at 100% 18.9 KW c)The level of transformer should be Level 3 d) Please refer tender item VIII D clause 2 -standard it should be as per IS 1180, also refer technical data sheet of transformer Annexure I A item no 3		
6		HT Switch Board	We request you to accept/consider M/s Sanjay Technical Services, Hyderabad	No deviation accepted in the make list it should be as per tender clause VIII M		
7	M/s Swastik Habitates (I) Pvt Ltd	We request you to add following brand products also to the specified product brand list,				
		Wires PVC insulated and PVC sheathed FR/FRLS/control wires (IS Marked)	Polycab			
		Instrumentation and control cable	Polycab			
		PVC/XLPE insulated LT cables	Polycab			
		Ceiling Fans/Wall Fans/ Cabin Fans	Grompton			
		HT/LT Transformers	CG Power			
		HT-SF-6 Circuit Breakers/VCB	CG Power			
		FLP Light Fixture	CG Power			
				No deviation accepted in the make list it should be as per tender clause VIII M		



**KARNATAKA ANTIBIOTICS &  
PHARMACEUTICALS LIMITED**

**KARNATAKA ANTIBIOTICS AND PHARMACEUTICALS LIMITED Bengaluru-58**  
**BULK DRUG - 7ACA Project**

**PRE BID QUERIES FOR ELECTRICAL HT WORK TENDER Dt.: 13<sup>TH</sup> OCTOBER-2023**



**DOSHI CONSULTANTS PVT. LTD.**

**Tender Ref no : KAPLBDP/CG/1482**

**NOTE: This Prebid Queries is part of the tender document and this supercedes the clauses of Tender**

A. TECHNICAL POINTS		KAP/DCPL COMMENTS/JUSTIFICATION	
Sl. No.	NAME OF THE COMPANY/VENDOR	PARTICULARS	SUPPLIER REMARKS
8	Ms Polypase engineering	HT panel system integration	We had provided a complete make list of all electrical item , please refer tender clause Villi M , HT panel should be as per make only
9	Ms Terco System and switch gear	DG synchronizing panel	DG synchronizing panel is not a part of this tender
		Boq item A 1, 19 33 KV copper XLPE cable 3 C x 300 sq mm	Yes copper XLPE cable quantity can be merge in 33 KV Aluminium XLPE cable 3 C x 400 sq mm which is mention in BOQ as optional, bidder can quote the qty in the item
		Trench will have cable MS supports provided -+Trey or it will be directly buried in ground	Cable will be buried directly in the ground , excavation and refilling of trench for cable are excluded (Civil work) from scope of electrical bidder. However cable laying etc. are in scope of electrical bidder
		Earthing 3 mtr pipe will be difficult ,	It is advisable to do place earthing with excavation to other option
		HT -T yard 2 is not shown in plan	Location required
		Liasoning and approval	It is shown in revised site plan which is uploaded with pre bid query
		Electrical estimate approval	Challan pertaining to permission (statutory payment) will have to paid by KAPL
		contract demand	it is approved or not , the same is in whose scope as this is further additional cost, normally this is done by client engineer team. This is very costly work
10	Ms Vedang	Liasoning work	It will be 9.9 MVA The mandatory statutory fees shall be borne by KAPL. All other type of Liasoning work and approval from MPEB will be under scope of electrical bidder

**List of Vendor present for Pre-Bid Queries**

Mr Polypase	Ms SRR	Ms Vedang	Ms Terco system
Mr Somshakar	Mr. Sai Gopi	Mr. Vivek Joshi	Mr. Pavitra
Ms Deepak panichetty	Mr. Prasad		
Mr. Deepak			

K P Rajan  
KAPL -Consultant

DCPL  
KAPL - Consultant

N.C. Mahesh  
(DGM - Formulation)

B. V. Kemat  
(GM - Technical)

V.R. Hemant Babu  
(M – Bulk Drug Project)

Somnath Datta  
(AGM – Bulk Drug Project)

Shalish Kumar  
(GM – Bulk Project)