



KARNATAKA ANTIBIOTICS AND PHARMACEUTICALS LIMITED
Bengaluru-58



BULK DRUG - 7ACA Project

NOTE: This Pre-bid Queries is part of the tender document and this supercedes the clauses of Tender
Pre-Bid Queries Dt: 13/10/2023
Tender Ref no :KAPL/BDP/SR/1486

Sl. No.	Company Name	Bid Document Ref. No.	Queries Raised	KAPL Clarifications
2.6			Is this Surface Excavation or Footing Excavation	
2.26.1			This item is already given in 2.6 as excavation in all kinds of soil with qty of 3206 cum	For footing excavation please refer item no. 2.6 & beyond 1.5 mm depth refer item (2.26.1)
4.7&4.7.1			Once again it has been repeated Precast concrete block - Clarify on this specification is Required	Mix ratio is already given
11.26			Size of Stone & Basic cost to be considered	size of Kota stone (600x600 mm)
11.56			For Polished Granite Flooring - Basic rate of granite is required	for basic rate please refer (SOR 2021)
11.56.1			Basic Rate of Granite required	for basic rate please refer (SOR 2021)
11.46			Basic rate of Vitrified Tile is required	for basic rate please refer (SOR 2021)
11.46.2			For fabric GI Fencing - A detailed drawing required	Drawing will be uploaded with Pre-Bid MOM
16.7			Brick Tiling Item is mentioned as to be paid separately, but the line item is nowhere included in the BOQ	please remove this item (no need)
22.6			A detailed drawing required	
SI. NO. 41			Detailed drawing required to arrive costing per sqm	Drawing will be uploaded with Pre-Bid MOM
SI. NO. 53			Detailed drawing required to arrive costing per sqm	Drawing will be uploaded with Pre-Bid MOM
SI. NO. 54			A detailed drawing including civil works & control room details required	Drawing will be uploaded with Pre-Bid MOM
SI. NO. 77			Can the 100% of EMD amount be given as BG.	Yes
2.1			We presume the Unit of measurement as Cum, Kindly Confirm.	cum
2.6			We presume the Unit of measurement as Cum, Kindly Confirm.	cum
NON-SOR			Kindly Clarify - No extra lift is payable if work is done by mechanical means	No extra lift will be paid if excavation is done by machine
5.9.1			We presume this as PPGI Sheet of 0.5mm thick, Kindly confirm.	yes it can be applicable
			We presume separate payment shall be paid for concrete surface which is either hidden from view or is specified to be separately finished with plaster, Kindly confirm.	no it is included
22.6			We could not able to find the relevant item to brick filling in the SOR. Please clarify	



KARNATAKA ANTIBIOTICS AND PHARMACEUTICALS LIMITED
Bengaluru-58



BULK DRUG - 7ACA Project

Pre-Bid Queries Dt. 13/10/2023
Tender Ref no :KAPL/BDP/SR/1486

NOTE: This Pre-bid Queries is part of the tender document and this supercedes the clauses of Tender		Queries Raised	KAPL Clarifications
SL No.	Company Name	Bid Document Ref. No.	
2	SRR PROJECTS PVT. LTD		
		(a) after surface preparation, first layer of slurry of cement @ 0.488 kg/sqm mixed with water proofing cement compound @ 0.253 kg/sqm.	
		(b) laying second layer of Fibre glass cloth when the first layer is still green. Overlaps of joints of fibre cloth should not be less than 10 cm.	
		(c) third layer of 1.5 mm thickness consisting of slurry of cement @ 1.289 kg/sqm mixed with water proofing cement compound @ 0.670 kg/sqm and coarse sand @ 1.289 kg/sqm. This will be allowed to air cure for 4 hours followed by water curing for 48 hours. The entire treatment will be taken upto 30 cm on parapet wall and tucked into groove in parapet all around.	
		(d) fourth and final layer of brick tiling with cement mortar (which will be paid for separately.	
		For the purpose of measurement the entire treated surface will be measured.	

we have removed this item and added NON SOR (item no. 43)

For Doshi Consultants		For KAPL			
Prepared By	Reviewed By	Forwarded By	Reviewed By	Checked By	Approved By
Ayori	Shushan Kuikarni	Hemanth Babu	Somnath Datta	Rajan Panicker	Shajesh Kumar