



ENQUIRY REF. No.	KAPL/ME/013/0235
DATE	07/05/2024
DUE DATE	09/05/2024 TILL: 13.00 HRS

Dear Sir,

Please submit your lowest and competitive offer in a SEALED ENVELOPE, DULY SUPERSCRIBING OUR ABOVE ENQUIRY REF. NO., DATE and DUE DATE on it/ OR MAIL, with other details of F.O.R terms, Taxes, Credit period, Delivery offered, Name of the Make, Detailed Specification etc., for below mentioned material/s

SL. NO.	ITEM CODE	ITEM DESCRIPTION	UOM	Q TY.
1	MDH3016	SWITCH LIMIT MCL-150 NO.:11067 FLP-3000	NOS	03
2	MDH3023	LOCKING DEVICE ASSEMBLY FLI JUNIOR PART NO.:35164	NOS	10
3	MDH2016	SEAL GROUP PART NO-110050-MODEL-FLP-2500(2011-BAC-	NOS	02
4	MDH3013	THERMOSTAT PANEL MOUNT PART NO.:60720 FLP-3000	NOS	06
5	MDH3024	SHEET NEOPRINE RUBBER 2.5-3MM PART NO.:21826	NOS	15
6	MDH3025	SEAL, D-TYPE EPDM 21X17MM DOOR PART NO.:11007	NOS	15
7	MDH3014	HEATER FINNED 4FPI COIL 6.6KW NO.:10719 FLP-3000	NOS	02
8	MDH3026	SWITCH PRESSURE 20-300PASCAL, 604-9, NO.:E31360	NOS	04
9	MDH2015	ROTOR ASSY PART NO-43149 MODEL-FLP-2500MAKE-BRYAIR	NOS	01
10	MDH3023	ROTOR ASSY. 630X200MMSPROCKET NO.:43149 FLP-3000	NOS	01
11	MIC1016	INSTALLATION & COMMISSIONING CHARGES	NOS	01

PR# 2024F02560  
**ENGINEERING AND PROJECT DEPARTMENT**

**MATERIAL REQUISITION**

Date : 05/03/2024

To,  
 Engg. Stores

*Very Very Urgent*

Through : HOD - E&P

Machine Name and Details :

*Spares for  
 Dehumidifier 02404*

Sl. No. **685**

Section : *DPP3*

Following are the details :

Sl. No.	Item Code No.	Item Description	UOM	Qty.	Required Date	P.R. No. & Date	Remarks
01	MDH 3016	Switch limit MCL-15D Pt. No : 11067	nos	03			Required for 03 DPP3 Section
02	MDH 3023	Locking device A/Sy FLI Junior Pt No: 35164	NDA	10			Dehumidifier 244 of Filley Room
03	MDH 2016	Seal group for 2500/3000 Pt no: 110050	Nos.	02			Filley Cabinet
04	MDH 3013	Thermostat panel mount Pt no: 60720	NDA	06			

*[Signature]*  
 JE / E / AM / DM / M

*[Signature]*  
 E&P

*[Signature]*  
 DM [MKM]

*[Signature]*  
 05/03/24  
 SM [SRO]

# ENGINEERING AND PROJECT DEPARTMENT

## MATERIAL REQUISITION

To,  
Engg. Stores

Date : 05/03/2024

Through : HOD - E&P

Machine Name and Details :

*Spares for Dehumidifier 2 & 4*

Sl. No.

686

Section :

*DPP3*

Following are the details :

Sl. No.	Item Code No.	Item Description	UOM	Qty.	Required Date	P.R. No. & Date	Remarks
05.	MDH3024	Sheet, neoprene, Rubber 2.5-3mm <u>Pt no:</u> 21826	mts	15			Required for DPP3 Section Dehumidifier 2 & 4
06.	MDH3025	Seal, O Type EPDM 21 x 17mm Door <u>Pt no:</u> 11007	mts	15			* The Dehumidifier 4 is under breakdown & not using.
07.	MDH 3014	Heater Finned HFPI Coil 6.6KW <u>Pt No:</u> 10719	nos.	02			* For Dehumidifier 2 is desiccant motor bed got choked
08.	MDH3026	Switch pressure 20-300Pa, 604-9 <u>Pt no:</u> E31360	Nos.	04			due to high air pressure it is not working.

*[Signature]*  
JE / E / AM / DM / M *[Signature]*

*[Signature]*  
DM [MKM]

*[Signature]*  
05/03/24  
SM [SRD]

Yours faithfully,  
for Bry-Air

# ENGINEERING AND PROJECT DEPARTMENT

## MATERIAL REQUISITION

Date : 05/03/2024

Engg. Stores

Through : HOD - E&P

Machine Name and Details : *Spares for Dehumidifier 2 & 4*

SI. No. **687**

Section : *OPP3*

Following are the details :

Sl. No.	Item Code No.	Item Description	UOM	Qty.	Required Date	P.R. No. & Date	Remarks
09.	MDH 2015	Rotor Assy 630x200mm Sprocket type Pt no: 43149 SE no: 2011-BAC - 15054 model : FLP-2500 make: Bry air	NDA	01			Required for OPP3 Section Dehumidifier 2 & 4 of Filly Room & Filly Cab
10.	MDH 3021	Rotor Assy 630 x 200mm Sprocket type Pt no: 43149 SE no: 2011-15055 Model: FLP-3000 make: Bry air	NDA	01			
11.	MIC 1016	The above materials should be supply & Commission/Installation.	Lot	01			

*[Signature]*  
JE [RAV]  
JE / E / AM / DM / M

*[Signature]*  
E [SCT]

*[Signature]*  
DM [MROV]

*[Signature]*  
SM [SRO] 03/24

Signature  
(on of above)

Yours faithfully,  
*[Signature]*

## INSTALLATION SITE VISIT REPORT

(Please write complete address, Phone, Fax &amp; E-Mail Nos.)

M/S Karnataka Antibiotics pharmaceuticals  
 2nd phase peenya industrial area  
 Bengaluru - 560058  
 mobile No. 8892343950

Had  
 W.O. :

DD/HV/AE No. :

Product Model :

Sr. No. :

With reference to your request: Inspection visit

our representative Hanish has visited on 23-01-2024 at \_\_\_\_\_ a.m. / p.m.  
 to \_\_\_\_\_ a.m. / p.m. and done / observed the following :

Checked units and Recommended required spares

- |  |   |
|--|---|
| ① <u>FLP-2500</u> .. sr. no. <u>2011-BAC-15054</u> | ② <u>FLP-1500</u> sr. no. <u>2010-BAC-13072</u> |
| ① Desiccant rotor - 01 no                          | ① Desiccant rotor - 01 no                       |
| ② Seal group - 01 no                               | ② Thermostat - 03 nos                           |
| ③ Thermostat - 03 nos                              | ③ Seal group - 01 no                            |
| ④ pressure switch - 02 nos                         |   |
| ⑤ limit switch bed - 02 nos                        |   |

[Signature] 23.01.24  
 F.C.T.

Customer Signature  
 (in confirmation of above)

[Signature]  
 Yours faithfully,  
 for Bry-Air (Asia) Pvt. Ltd.