



ENQUIRY REF. No.	K-E&P/SR/0196/2025-26
DATE	13.05.2025
DUE DATE	19.05.2025 till 1:00 PM

Dear Sir,

Please submit your lowest and competitive offer in a SEALED ENVELOPE, DULY SUPERSCRIBING OUR ABOVE ENQUIRY REF. NO., DATE and DUE DATE on it. Mentioned other details of F.O.R terms, Taxes, Credit period, Delivery offered, Name of the Make, Detailed Specification etc., for the below Supply or Service

SI No	Item Code	Item Description	Uom	Qty
01	---	REPAIRING AND SERVICING OF 3 NOS OF HITACHI OUTDOOR UNITS	NOS.	03
2		PRESSURE LEAK TEST TO BE CONDUCTED FOR ALL OUTDOOR UNITS		
3		VACUUM HOLD TEST TO BE DONE FOR ALL OUTDOOR UNITS		
4		REFRIGARENT FILLING TO BE DONE FOR ALL OUTDOOR UNITS		

DETAILS AS MENTIONED IN THE REPAIR ADVICE NOTE ENCLOSED

Please ensure that your offer reaches us on or before Due Date by courier OR Speed post or by Hand in sealed cover to below office address or email to purennp@kaplindia.com:

M/s. Karnataka Antibiotics and Pharmaceuticals Limited
Plot No.37, Arka The Business Centre, NTTF Main Road, Peenya Industrial Area
2nd Phase, Bengaluru-560058 Ph. No.080-23571590

NOTE:

01. PLEASE VISIT OUR SITE FOR BETTER UNDERSTANDING THE SCOPE OF WORK
02. IF YOU ARE NOT PARTICIPATING IN THE TENDER PLEASE SEND A REGRET LETTER.
03. VENDOR HAS TO QUOTE AS PER OUR TENDER IN YOUR COMPANY LETTER HEAD.

IF YOU NEED ANY CLARIFICATION, PLEASE CONTACT US.

Thanking you,

Yours faithfully,
For KARNATAKA ANTIBIOTICS
& PHARMACEUTICALS LIMITED


YUVARAJA. M
DY. MANAGER – PURCHASE DEPT.
MOB: 9945317873

Sent to Proc Approval 24/3/25

KARNATAKA ANTIBIOTICS AND PHARMACEUTICALS LIMITED

REPAIR ADVICE NOTE/~~INTER DEPARTMENTAL NOTE~~

Page : 1 of 1

E&P.

RAN Number : 2025F00096

: PURCHASE.

For Dept : DPP3.

RAN Date : 18/03/2025

Project Type : Operational Budget

Status : GENERATED

Subject Matter : REPAIRING AND SERVICING OF 3 NOS OF OUTDOOR UNITS OF STORE'S AHU, IN DPP3 DEPT.

Engg Name : SHIVU RAMU

Mob Numbr : 8892343950,9738362903.

SI No Advice Description

- 1 REPAIRING & SERVICING OF 3 NOS OF HITACHI OUTDOOR UNITS.
- 2 PRESSURE LEAK TEST TO BE CONDUCTED FOR ALL OUTDOOR UNITS.
- 3 VACUUM HOLD TEST TO BE DONE FOR ALL OUTDOOR UNITS.
- 4 REFRIGERANT FILLING TO BE DONE FOR ALL OUTDOOR UNITS.

-----REMARKS-----

SI No RAN Note

- 1 THE VENDOR MUST VISIT THE SITE IN ORDER TO UNDERSTAND THE SCOPE OF WORK BEFORE QUOTATION.
- 2 LEAKAGE ARRESTING TO BE DONE WITH NECESSARY MATERIALS BY THE VENDOR ONLY.
- 3 ANY BRAZING AND WELDING WORKS COMES UNDER VENDOR'S SCOPE ONLY.
- 4 PLEASE REFER THE ATTACHMENT FOR THE DETAILS OF OUTDOOR UNITS SPECIFICATIONS.

HITACHI

PACKAGED AIR CONDITIONER

DUCTABLE TYPE

MODEL NO. CCS0102SRHDDA3

SERIAL NO. 210020365

POWER SUPPLY: 400 V, 3 Phase, 50 Hz.

CAPACITY 29895W

POWER INPUT 9190W

COP -

CURRENT 15.0A

MAXIMUM PRESSURE 42.7kg/cm²

REFRIGERANT R410A 2.7 X 2Kg

Compressor No.1 EDDN1ED1SP5U

Compressor No.2 EDDN1ED1SP5H

Compressor No.3

Fan Motor No. 1 LMLK4250J2153144

Fan Motor No. 2

Johnson Controls - Hitachi
Air Conditioning India Ltd.

 **R410A**

HITACHI

PACKAGED AIR CONDITIONER

DUCTABLE TYPE

MODEL NO. CCS0102SRHDDA3

SERIAL NO. 210020368

POWER SUPPLY: 400 V, 3 Phase, 50 Hz.

CAPACITY 29895W

POWER INPUT 9190W

COP -

CURRENT 15.0A

MAXIMUM PRESSURE 42.7kg/cm²

REFRIGERANT R410A 2.7 X 2Kg

Compressor No.1 EDDN1ED1SP80

Compressor No.2 EDDN1ED1SP02

Compressor No.3

Fan Motor No. 1 LMLK4250J2153154

Fan Motor No. 2

Johnson Controls - Hitachi
Air Conditioning India Ltd.

 **R410A**

HITACHI

PACKAGED AIR CONDITIONER

DUCTABLE TYPE

MODEL NO. CCSG102SRHDDA3

SERIAL NO. 210C50696

POWER SUPPLY: 400 V, 3 Phase, 50 Hz.

CAPACITY 29895W

POWER INPUT 9190W

COP -

CURRENT 15.0A

MAXIMUM PRESSURE 42.7kg/cm²

REFRIGERANT R410A 2.7 X 2Kg

Compressor No.1 EDDN1ED1NSHN

Compressor No.2 EDDN1ED1NSWH

Compressor No.3

Fan Motor No. 1 LMLK4250A2149731

Fan Motor No. 2

Johnson Controls - Hitachi
Air Conditioning India Ltd.

 **R410A**